

# Fire Fight Safety Solutions

FFSS



FIRE EXTINGUISHER



FIRE ALARM SYSTEM



ESCAPE SIGNAGES



AMC



HYDRANT & SPRINKLER SYSTEM



ISO

Off. No 7A/204, "Kalplaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027

☎ : 020-65112299, ☎ . 9970548822, ✉ info@ffss.in, 🌐 www.ffss.in

Ref: FFSS /2026-27/A- 07

Date: 05 Jan 2026

## Form B

[See Section 3(3) and rule 4(2)]

One Year Certificates to be given in every JAN & DEC by the owner or the occupier for Compliance of Fire prevention and life safety measures.

## Certificate

Certified that I/We have carried out inspection of the fire prevention and life safety measures Installed in the following building or premises, namely: -


**"M/S. ASHVIN RURAL AYURVED COLLEGE"**

**ADDRESS: MANCHI HILL, ASHVI BK, TAL -SANGAMNER,  
DISTRICT AHILYANAGAR - 413714.**

I/we further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient conditions during the period one Year (5<sup>th</sup> JAN 2026 to 31<sup>st</sup> DECEMBER 2026), as required under the provision of Maharashtra Fire Prevention and Life safety Measures Act, 2006 (MAH III of 2007). The details of the inspection of the installations carried out by me/ we are mentioned in the report appended here with.

Place: Pune

Date: 05 JAN 2026



*[Signature]*  
Fire Fight Safety Solutions

*[Signature]*  
Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Hill, Ashvi Bk, Tal. Sangamner  
Dist. Ahmednagar, Pin-413714

# Fire Fight Safety Solutions

FFSS



FIRE EXTINGUISHER



FIRE ALARM SYSTEM



ESCAPE SIGNAGES



AMC



HYDRANT & SPRINKLER SYSTEM



ISO

Off. No 7A/204, "Kalptaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027

☎ : 020-65112299, ☎ : 9970548822, ✉ : info@ffss.in, 🌐 : www.ffss.in

Ref: FFSS /2026-27/A- 13

Date: - 05 Jan 2026

## NO OBJECTION CERTIFICATE (FIRE SAFETY)

**Name of Institution:** Ashvin Rural Ayurved College

**Address:** Manchi Hill, Ashvi BK, Sangamner, Dist. Ahilyanagar

**Audited By:** Fire Fight Safety Solutions

**Original NOC Date:** 05/01/2026

This is to certify that Ashvin Rural Ayurved College was inspected and audited for fire safety on 03-01-2026 by the team of Fire Fight Safety Solutions. The fire safety work has been completed, and all required safety norms were followed by the workers during execution. Necessary precautionary measures were taken before commencement of work.

It is observed that sufficient fire extinguishers and safety equipment are available on the college premises as per prescribed safety standards.

**Validity:** This Fire Audit Report is valid for One Year from the date of inspection.

**Note:**

1. It is the responsibility of the owner/management to maintain all fire extinguishers in properly charged and working condition on the college premises at all times.



For Fire Fight Safety Solutions

Fire Fight Safety Solutions

Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Hill, Ashvi Bk., Tal. Sangamner  
Dist. Ahmednagar, Pin-413714

# Fire Fight Safety Solutions



Off. No 7A/204, "Kalptaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027

☎ : 020-65112299, ☎ : 9970548822, ✉ : info@ffss.in, 🌐 : www.ffss.in

Ref: FFSS /2026-27/A- 08

Date: - 05 Jan 2026

## Form B

[See Section 3(3) and rule 4(2)]

One Year Certificates to be given in every JAN & DEC by the owner or the occupier for Compliance of Fire prevention and life safety measures.

### Certificate

Certified that I/We have carried out inspection of the fire prevention and life safety measures Installed in the following building or premises, namely: -

**"M/S. ASHVIN RURAL AYURVED HOSPITAL"**

**ADDRESS: MANCHI HILL, ASHVI BK, TAL -SANGAMNER,  
DISTRICT AHILYANAGAR - 413714.**

I/we further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient conditions during the period one Year (5<sup>th</sup> JAN 2026 to 31<sup>st</sup> DECEMBER 2026), as required under the provision of Maharashtra Fire Prevention and Life safety Measures Act, 2006 (MAH III of 2007). The details of the inspection of the installations carried out by me/we are mentioned in the report appended here with.

Place: Pune

Date: 05 JAN 2026



Fire Fight Safety Solutions

*Apca*  
Principal  
Ashvin Rural Ayurved College & Hospital  
Manchi Hill, Ashvi Sk., Tal. Sangamner  
Dist. Ahmednagar, Pin-413714

# Fire Fight Safety Solutions



Off. No 7A/204, "Kalptaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027  
☎ : 020-65112299, ☎ : 9970548822, ✉ : info@ffss.in, 🌐 : www.ffss.in

Ref: FFSS /2026-27/A- 12

Date: - 05 Jan 2026

## NO OBJECTION CERTIFICATE (FIRE SAFETY)

**Name of Institution:** Ashvin Rural Ayurved Hospital

**Address:** Manchi Hill, Ashvi BK, Sanganner, Dist. Ahilyanagar

**Audited By:** Fire Fight Safety Solutions

**Original NOC Date:** 05/01/2026

This is to certify that Ashvin Rural Ayurved Hospital was inspected and audited for fire safety on 03-01-2026 by the team of Fire Fight Safety Solutions. The fire safety work has been completed, and all required safety norms were followed by the workers during execution. Necessary precautionary measures were taken before commencement of work.

It is observed that sufficient fire extinguishers and safety equipment are available on the college premises as per prescribed safety standards.

**Validity:** This Fire Audit Report is valid for One Year from the date of inspection.

**Note:**

1. It is the responsibility of the owner/management to maintain all fire extinguishers in properly charged and working condition on the college premises at all times.



For Fire Fight Safety Solutions

Fire Fight Safety Solutions

Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Hill, Ashvi Bk., Tal. Sanganner  
Dist. Ahilyanagar, Pin-413714



# Fire Fight Safety Solutions



FIRE EXTINGUISHER



FIRE ALARM SYSTEM



ESCAPE SIGNAGES



AMC



HYDRANT & SPRINKLER SYSTEM



ISO

Off. No 7A/204, "Kalptaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027

☎ : 020-65112299, ☎ : 9970548822, ✉ : info@ffss.in, 🌐 : www.ffss.in

## FIRE AUDIT

Fire Safety Audit Is Conducted On: - 03/01/2026

Hospital at Gat/ Survey No: - 294/1

Village: - Manchi Hill Ashvi bk, Tal: - Sangamner

Dist: - Ahilyanagar the observation is as under



Sr.no	Description of the building and fire safety measures etc.	Remarks if any
<b>(A) Information</b>		
1.	Name of the hospital	Ashvin Rural Ayurved Hospital Manchi Hill Ashvi Bk, Tal Sangamner, Dist. Ahilyanagar OK
2.	Year of construction	2000 OK
3.	Address	Manchi hill. Ashvi Bk, Tal-. Sangamner, Dist- Ahilyanagar OK
4.	Hospital telephone no	299132 OK
5.	Email .id	ashwinruralayurveda@gmail.com OK
6.	Hospital type	Charitable OK
7.	Hospital type specialty	Ayurved hospital OK
8.	Hospital bed capacity	200 OK
<b>(B) Budling Structural Details</b>		
9.	Budling Hight in mtrs	10mtrs OK
10.	Total no. of floors	2 OK
11.	Total B/u area in SQM	9996.60 Sq. Mtr OK
12.	Marginal open space around in building (sqm)	500 Sq.Mtr. OK
13.	No. of exit gates with width	3 OK
14.	No. of staircase with width	3 OK
15.	No. of wards	12 OK
16.	Total toilet block per floor	6 OK

*[Signature]*

Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Hill Ashvi Bk., Tal. Sangamner  
Dist. Ahilyanagar, Pin-413714




17.	Exterior cascading / cladding of building	2B	OK
18.	Overhead water tank capacity	10000Lit	OK
19.	Underground water tank capacity	5000Lit	OK
20.	Total no. of lift	1	OK
21.	Canteen / pantry / kitchen details	2	OK
22.	Location of laundry. If any	Basement	OK
23.	Detail of air conditioning	8	OK
24.	Store room detail	3	OK
25.	Transformer / generator location with capacity	30kv.around backside of hospital	OK
26.	Total capacity of patient accommodation in building	180	OK
27.	Radiology maternal / machinery if any name	X-Ray Machine Only	OK
28.	Spirit / sanitizer storage details	Keep in Store room only	OK
29.	Oxygen cylinder / tank utility details	10 cylinders	OK
30.	Total no of employee	Doctors: -40 Nurse: -80 Others: -40 Security: -08 Cleaning: -15	OK


**(C) Government permission details**

31.	Budling plan approval	Yes	OK
32.	Budling completion certificate	Yes	OK
33.	Fire NOC obtained	Yes	OK
34.	Fresh form - B Obtained?	Yes	OK
35.	Name of license agency	Fire Safety Solution Pune	OK

**(D) active fire protection**

36.	Refuge area details	Yes	OK
37.	Firefighting pump details with capacity	7.5HP -2 100HP-2 Disel Gentrator-100HP	OK

  
**Principal**  
 Ashvin Rural Ayurved College & Hospital  
 Manchi Hill, Ashvin Pk., Tal. Sangarner  
 Dist. Ahmednagar, Pin-413714



39.	Extinguishers details	AHC-25	OK
	- Hose reel hose	Available in every dept.	OK
	- Stand riser / down	Yes	OK
	- Stand hydrant system	Yes	OK
	- Sprinkler system	Yes	OK
43.	Fire alarm / MCP	Yes	OK
44.	Automatic detection system	Yes	OK
45.	Sign indicators	Yes	OK
46.	Fire bandage connection	Yes	OK
47.	LPG / LNG Detectors	Yes	OK
48.	Firefighting water tank capacity	Yes	OK
49.	Automatic fire dampers provided in central ac ducts	Yes	OK
50.	Fire doors details	Exit Door Available	OK
51.	Fire plans installed in each ward	Yes	OK
52.	Fire emergency details board installed	Yes	OK
53.	Firefighting staff details. If any	Fire Safety Officer Is appointed in Hospital premises	OK
<b>(E) fire prevention and awareness measures</b>			
54.	Fire mock drill conducted	Yes	OK
55.	Whether Evacuation Drills conducted	Yes	OK
56.	Emergency contact person details	Mr. Salim Shaikh	OK


Recommendation for fire fighting system.


I hereby certify that the information provide by me is true.

Hospital Incharge: -

Name: - Dr. Sanjeev Bapurao Lokhande

Post: -Medicine (HOD)

  
Signature and seal



For Fire Fight Safety Solutions

  
Fire Fight Safety Solutions

  
Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Mill, Ashwi Bk., Tal. Sangamner  
Dist. Amravati, Pin-437114

# Fire Fight Safety Solutions



Off. No 7A/204, "Kalplaru Estate", Phase-III, Jawalkar Nagar, Pimple Gurav, Pune - 411027  
 ☎ : 020-65112299, ☎ : 9970548822, ✉ : info@ffss.in, 🌐 : www.ffss.in

## FIRE AUDIT



The Fire Safety Audit Is Conducted On: - 03/01/2026

College at Gat/ Survey No: - 294/1

Village: - Manchi Hill Ashvi bk, Tal: - Sangamner

Dist: - Ahilyanagar the observation is as under

Sr.no	Description of the building and fire safety measures etc.	Remarks If any
<b>(A) Information</b>		
1.	Name of the College	Ashvin Rural Ayurved College Manchi Hill Ashvi Bk, Tal Sangamner, Dist. Ahilyanagar
2.	Year of construction	2000
3.	Address	Manchi hill. Ashvi Bk, Tal-. Sangamner, Dist- Ahilyanagar
4.	College telephone no	02425-297005
5.	Email .id	ashvin.ayurved@gmail.com
6.	College type	Private
7.	College type specialty	Ayurved College
8.	College Intake capacity	100
<b>(B) Budling Structural Details</b>		
9.	Budling Hight in mtrs	10mtrs
10.	Total no. of floors	3
11.	Total B/u area in SQM	7739.92 Sq. Mtr
12.	Marginal open space around in building (sqm)	700 Sq. Mtr
13.	No. of exit gates with width	02
14.	No. of staircase with width	02
15.	No. of Department & Classroom	19


*[Signature]*  
Principal

Ashvin Rural Ayurved College & Hospital  
 Manchi Hill, Ashvi Bk., Tal. Sangamner  
 Dist. Ahilyanagar, Pin-413714



16.	Total toilet block per floor	06	OK
17.	Exterior cascading / glazing of building glass	28	OK
18.	Overhead water tank capacity	10000Lit	OK
19.	Underground water tank capacity	5000Lit	OK
20.	Total no. of lift	1	OK
21.	Canteen / pantry / kitchen details	2	OK
22.	Location of laundry. If any	Basement	OK
23.	Detail of air conditioning	8	OK
24.	Store room detail	3	OK
25.	Transformer / generator location with capacity	30kv.around backside of College	OK
26.	Total capacity of patient accommodation in building	180	OK
27.	Radiology maternal / machinery if any name	NA	NA
28.	Spirit / sanitizer storage details	Keep in Store room only	OK
29.	Oxygen cylinder / tank utility details	NA	NA
30.	Total no of employee	Doctors: -64 Non-Teaching Staff-88 Students - 570	OK
<b>(C) Government permission details</b>			
31.	Budling plan approval	Yes	OK
32.	Budling completion certificate	Yes	OK
33.	Fire NOC obtained	Yes	OK
34.	Fresh form - B Obtained?	Yes	OK
35.	Name of license agency	Fire Safety Solution Pune	OK
<b>(D) active fire protection</b>			
36.	Refuge area details	Yes	OK
37.	Firefighting pump details with capacity	7.5HP-2 100HP-2 Disel Genrator-100HP	OK

  
**Principal**  
 Ashvin Rural Ayurved College & Hospital  
 Manchi Hill, Ashvi Bk., Tal. Sangamner  
 Dist. Ahmednagar, Pin-413714



38	Extinguishers details	MIC 20	OK
39	Hose reel hose	Available in every drpt.	OK
40	Ward riser / down corner	Yes	OK
41	Yard hydrant system	Yes	OK
42	Sprinkler system	Yes	OK
43	Fire alarm / mcp	Yes	OK
44	Automatic detection system	Yes	OK
45	Sign indicators	Yes	OK
46	Fire bandage connection	Yes	OK
47	LPG / LNG Detectors	Yes	OK
48	Firefighting water tank capacity	Yes	OK
49	Automatic fire dampers provided in central ac ducts	Yes	OK
50	Fire doors details	Exit Door Available	OK
51	Fire plans installed in each ward	Yes	OK
52	Fire emergency details board installed	Yes	OK
53	Firefighting staff details. If any	Fire Safety Officer Is appointed in College premises	OK
(E) fire prevention and awareness measures			
54	Fire mock drill conducted	Yes	OK
55	Whether Evacuation Drills conducted	Yes	OK
56	Emergency contact person details	Mr. Salim Shaikh	OK

Recommendation for fire fighting system.

I hereby certify that the information provide by me is true.

College Incharge: -

Name: - Dr. Shyamal Prakash Nirmal

Post: -Principal

Signature and seal



For Fire Fight Safety Solutions



Fire Fight Safety Solutions

Principal

Ashvin Rural Ayurved College & Hospital  
Manchi Hill, Ashvi Bk., Tal. Sanganner  
Dist. Aharednagar, Pin-413714